HOW TO CHANGE TEMPERATURE SCALE

INSTRUCTIONS FOR Carrier BRAND EQUIPMENT

SELECT





On the keypad, press CODE SELECT.



Press the arrow up or down until you see Cd28, then press ENTER.



DEFROST/ LIST INTERVAL ENTER RETURN SUPPLY BATTERY ALT. MODE POWER Wait until you see the

C or F blinking, then use one of the arrow keys to switch from C to F, or from F to C. **Press ENTER within 5** seconds to set the selected scale. The temperature scale is now changed.

Tropical

For further assistance. call one of the following telephone numbers.

Business Hours 561-840-2949

After Hours

561-762-4266 561-373-4479

561-307-6638

561-373-0878

www.tropical.com